Industrial Stormwater General Permit National Pollutant Discharge Elimination System (NPDES)

				Discharge	Monitoring Re	port (DMR)			
Site Name: ALASKAN COPPER WORKS						WAR000139		CB330001	
Site Address:	3200 6th	Avenue South						Samplin	g Point
City: Seattle		Co	unty: Kir	ng					
Submit one D	MR per s	ampling point.			Reporting Period	1	. 1		
1				Quarter (indicate)		Year: 2010 3 rd 4 th			
			⊠ Jan/F	eb/Mar L Apr	/May/Jun 📗 J	lul/Aug/Sept C	Oct/Nov/Dec		
<u>Parameter</u>	<u>Units</u>	Benchmark Va	alue	<u>Analytical</u>	<u>Laboratory</u>	Sample Results			
		(Effluent Lim	<u>it)*</u>	Method	Quantitation	SINGLE SAMPLE	SINGLE	AVERAGE	CONSISTENT
					Level	RESULT	SAMPLE	(If more than one sample	ATTAINMENT?
				est Nation			DATE	collected, complete additional sampling log on next page.)	(Condition S4.B.6)
						sale j	(MM/DD)	,	(✓ for yes)
Turbidity	NTU	25		EPA 180.1, Meter	0.5	57.4	02/11	N/A	
pН	s.u.	5 - 9		Meter	±0.5	7.17	02/11	N/A	
Zinc, Total	µg/L	117		EPA 200.8	2.5	193	02/11	N/A	
Oil Chasa	Vaa/Na	No visible sil shasa		A1/A	NI/A	01	00/44	NI/A	A1/A

	7.				1120021	D. 17	collected, complete additional	(Condition S4.B.6)		
	44.0		Teste energy			DATE	sampling log on next page.)	,		
	1.3				9-60	(MM/DD)		(✓ for yes)		
Turbidity	NTU	25	EPA 180.1, Meter	0.5	57.4	02/11	N/A			
рН	s.u.	5 - 9	Meter	±0.5	7.17	02/11	N/A			
Zinc, Total	μg/L	117	EPA 200.8	2.5	193	02/11	N/A			
Oil Sheen	Yes/No	No visible oil sheen	N/A	N/A	Sheen Present? ☐Yes / ⊠No	02/11	N/A	N/A		
Copper, Total	µg/L	Western WA: 14 Eastern WA: 32	EPA 200.8	2.0	163	02/11	N/A			
Lead, Total	μg/L	81.6	EPA 200.8	0.5	24.4	02/11	N/A			
Total	mg/L	10	NWTPH-Dx	0.1	5.7	02/11	N/A			
Petroleum										
Hydrocarbons (TPH)										
	solloatod	No otormuntor was disable	arand during narma	l working hours						
		 No stormwater was discharged 	•	•						
		 Stormwater was discharge 	ed during normal w	orking hours, but	a sample wasn't co	ollected (explai	n in comments sectio	n).		
ADDITIONAL C	OMMEN	TS:								
Certification Statement evaluated the information	nt I certify und	der penalty of law, that this document and a d. Based on my inquiry of the person or penalties aware that there are significant penalties	all attachments were prepared	d under my direction or su em, or those persons dire	upervision in accordance with ctly responsible for gathering	a system designed to information, the infor-	assure that qualified personne mation submitted is, to the best	properly gathered and of my knowledge and belief,		
James	Bvc	www. Downstup	in Man	ames	Drown		5/7/10			
Name / Title (printed) Signature (not valid unless signed). See Permit Date Signed Condition G2 for signature requirements.										